



NOTICE

GAS PIPE BONDING **CSSR (CORRUGATE STAINLESS STEEL TUBING)**

2009 IFGC 310.1 AND 2009 IRC G2411.1

NOTE: THIS IS AN ADDITION TO 2009 IFGC 310.1 AND 2009 IRC G2411.1 GAS PIPE BONDING

CSST gas piping systems shall be bonded to the electrical service grounding electrode system at the point where the gas service piping enters the building. The bonding conductor size shall not be less than #6 AWG copper wire or equivalent.

Three Points

1. This requires ALL CSSR GAS PIPING SYSTEMS to be bonded to the electrical service grounding electrode system, at the point where the gas service enters the building.
2. This requires the bonding jumper to be not smaller than 6AWG copper wire.
3. Tie in points to the grounding electrode system: ground rod, grounding electrode conductor #6AWG, or in the electrical panel (ONLY A QUALIFIED ELECTRICIAN CAN TIE INTO THE ELECTRICAL PANEL).

INSPECTION OF THE BONDING CONDUCTOR WILL BE DONE AT THE GAS FINAL OR ELECTRICAL FINAL